PGP-MONTHLY PERFORMANCE REPORT

SEPT - 2018

Prepared For

Tippecanoe Valley School Corporation

Blaine Conley, Superintendent of Tippecanoe Valley School Corporation

Todd Glenn, Director of Maintenance of Tippecanoe Valley School Corporation

Prepared & Submitted by:

PowerGrid Partners
Global Green Energy Solutions

www.powergridpartners.com

PowerGrid Partners
Global Green Energy Solutions

Wind Speed	**5.68**	m/s
Availability	**99.26**	%
Monthly Production	**67,239.00**	kWh

Date	Availability	Wind Speed	Production	Comments
01-Sep-18	99.98 %	5.7 m/s	176 kWh	n/a
02-Sep-18	100 %	7.1 m/s	3440 kWh	n/a
03-Sep-18	99.97 %	5 m/s	1550 kWh	n/a
04-Sep-18	100 %	5.7 m/s	1750 kWh	n/a
05-Sep-18	100 %	6.6 m/s	2834 kWh	n/a
06-Sep-18	91.56 %	3.4 m/s	943 kWh	n/a
07-Sep-18	100 %	5.5 m/s	1355 kWh	n/a
08-Sep-18	100 %	8.1 m/s	5886 kWh	n/a
09-Sep-18	100 %	9.5 m/s	9151 kWh	n/a
10-Sep-18	100 %	4.3 m/s	1211 kWh	n/a
11-Sep-18	99.46 %	3.6 m/s	591 kWh	n/a
12-Sep-18	100 %	4.5 m/s	752 kWh	n/a
13-Sep-18	100 %	4.4 m/s	748 kWh	n/a
14-Sep-18	99.97 %	4.2 m/s	545 kWh	n/a
15-Sep-18	100 %	5.2 m/s	1317 kWh	n/a
16-Sep-18	100 %	5.8 m/s	1795 kWh	n/a
17-Sep-18	100 %	3.4 m/s	272 kWh	n/a
18-Sep-18	100 %	4.5 m/s	913 kWh	n/a
19-Sep-18	100 %	5 m/s	1427 kWh	n/a
20-Sep-18	98.94 %	7.5 m/s	4201 kWh	n/a
21-Sep-18	92.72 %	9.2 m/s	7491 kWh	n/a
22-Sep-18	100 %	5.8 m/s	1644 kWh	n/a
23-Sep-18	100 %	6.1 m/s	1577 kWh	n/a
24-Sep-18	100 %	6.4 m/s	2601 kWh	n/a
25-Sep-18	100 %	6.9 m/s	3182 kWh	n/a
26-Sep-18	100 %	6.4 m/s	2832 kWh	n/a
27-Sep-18	100 %	5.1 m/s	1678 kWh	n/a
28-Sep-18	95.23 %	6.7 m/s	3507 kWh	n/a
29-Sep-18	100 %	3.2 m/s	206 kWh	n/a
30-Sep-18	100 %	5.6 m/s	1664 kWh	n/a

Note: ALL THE DATA IS REPORTED BY THE TURBINE CONTROL SYSTEM





DOWNTIME EXPLANATION (For availability less than 75%)

n/a.

For Queries, please email to

rkamble@powergridpartners.com

jfellhauer@powergridpartners.com

Note: ALL THE DATA IS REPORTED BY THE TURBINE CONTROL SYSTEM