



Monthly Performance Report

February 2015

for

Tippecanoe Valley School Corporation

Prepared for

Brett Boggs, Superintendent of Tippecanoe Valley School Corporation

Dr. Dan Kramer, Assistant Superintendent of Tippecanoe Valley School Corporation

Todd Glenn, Director of Maintenance of Tippecanoe Valley School Corporation

By:

Performance Services

4670 Haven Point Boulevard, Suite 200

Indianapolis, IN 46280

Tel: (317) 713-1750 Fax: (317) 713-1751

Contents

AVAILABILITY NUMBERS AND GRAPH.....	3 thru 4
DOWNTIME EXPLANATION.....	5
SCHEDULED MAINTENANCES.....	5

TOTAL POWER PRODUCTION REPORTED BY SCADA FOR FEBRUARY = 133,446.5 kWh



AVERAGE AVAILABILITY REPORTED BY SCADA FOR FEBRUARY = 99.26%

Date	Availability	Wind Speed	Production	Comments
	(%)	(m/s)	(kWh)	
February 1, 2015	100	6.78	6683	
February 2, 2015	100	6.74	5455	
February 3, 2015	100	7.32	4747.5	
February 4, 2015	100	7.51	5017	
February 5, 2015	97.75	4.98	2348	
February 6, 2015	100	7.53	5484	
February 7, 2015	100	8.6	7483	
February 8, 2015	100	7.27	5469.5	
February 9, 2015	100	7.22	3850	
February 10, 2015	100	4.94	1293.5	
February 11, 2015	100	7.36	4768.5	
February 12, 2015	100	8.72	8127.5	
February 13, 2015	100	6.8	4473.5	
February 14, 2015	85.83	10.85	10623.5	
February 15, 2015	100	4.64	966	
February 16, 2015	100	4.19	997	
February 17, 2015	95.72	6.48	3424	
February 18, 2015	100	9.76	10837	
February 19, 2015	100	9.19	9636.5	
February 20, 2015	100	7.92	7724.5	
February 21, 2015	100	2.68	268.5	
February 22, 2015	100	6.47	3700	
February 23, 2015	100	3.72	783	
February 24, 2015	100	10.38	13340	
February 25, 2015	100	5.46	2792	
February 26, 2015	100	5.65	1899.5	
February 27, 2015	100	3.51	575	
February 28, 2015	100	4.15	680	

Availability [%] – Percentage of daily uptime

Wind Speed [m/s] – Daily average wind speed in meters per second

Production [kWh] – Daily cumulative energy export in kilowatt hours



DOWNTIME EXPLANATION *(for availability less than 75%)*

Availability was at or above 85.83% for February 2015.

SCHEDULED MAINTENANCES

There were no scheduled maintenances for February 2015.